

# TYPE APPROVAL CERTIFICATE

Certificate No:  
**TAE00002X9**  
Revision No:  
**2**

## This is to certify:

That the Electric Power Cable

with type designation(s)

**TEXILine Power EMC 0,6/1kV,  
TEXILine Power VFD EMC 1,8/3kV,  
TEXILine Power VFD EMC 3G 1,8/3kV,  
TEXILine Power VFD EMC Soft 1,8/3kV,  
TEXILine Power Heli Twist Cu EMC**

Issued to

**amo specialkabel AB  
ALSTERMO, Sweden**

is found to comply with

**DNV rules for classification – Ships, offshore units, and high speed and light craft**

## Application :

**General power and lighting. VFD version for variable frequency drives.**

**Products approved by this certificate are accepted for installation on all vessels classed by DNV.**

Type	Rated voltage (kV)	Temp. class (°C)
TEXILine Power EMC 0,6/1kV	0,6/1	90
TEXILine Power VFD EMC 1,8/3kV	1,8/3kV	90
TEXILine Power VFD EMC 3G 1,8/3kV	1,8/3kV	90
TEXILine Power VFD EMC Soft 1,8/3kV	1,8/3kV	90
TEXILine Power Heli Twist Cu EMC	0,6/1 kV	90

Issued at **Høvik** on **2023-07-03**

This Certificate is valid until **2028-05-28**.

for **DNV**

DNV local unit: **Malmö**

Approval Engineer: **Ivar Bull**

.....  
**Frederik Tore Elter**  
**Head of Section**

This Certificate is subject to terms and conditions overleaf. Any significant change in design or construction may render this Certificate invalid.  
The validity date relates to the Type Approval Certificate and not to the approval of equipment/systems installed.

LEGAL DISCLAIMER: Unless otherwise stated in the applicable contract with the holder of this document, or following from mandatory law, the liability of DNV AS, its parent companies and their subsidiaries as well as their officers, directors and employees ("DNV") arising from or in connection with the services rendered for the purpose of the issuance of this document or reliance thereon, whether in contract or in tort (including negligence), shall be limited to direct losses and under any circumstance be limited to 300,000 USD.



## Product description

Types: RXZ-HF EMC 0,6/1kV,  
 RXZ-HF VFD EMC 1,8/3kV,  
 RXZ-HF VFD EMC 3G 1,8/3kV  
 RXZ-HF VFD EMC Soft 1,8/3kV

### Construction:

Conductors: Plain/tinned, stranded copper class 2 or class 5  
 Core insulation: HF XLPE  
 Filler: Flame retardant halogen-free compound  
 Inner covering: Lapped or extruded  
 Screen (if any): Metal backed PE tape  
 Metal covering: Plain/tinned copper wire braid or galvanised steel wire braid  
 Outer sheath: SHF 1

### RXZ-HF EMC 0,6/1kV:

No of cores:	Cross sectional area [mm <sup>2</sup> ]
1	1,5 - 300
2	1,5 - 95
3	1,5 - 240
4	1,5 - 95
5	1,5 - 25
6, 7, 10, 12, 14, 16, 19, 24, 25, 27, 37	1,5
7, 9, 10, 14, 16, 19, 24, 27, 37	2,5

### RXZ-HF VFD EMC 1,8/3kV:

No of cores:	Cross sectional area [mm <sup>2</sup> ]
3	16 -240
4	95

### RXZ-HF VFD EMC 3G 1,8/3kV:

No of cores:	Cross sectional area [mm <sup>2</sup> ]
3/3E	16/2,5 – 240/50

### RXZ-HF VFD EMC Soft 1,8/3kV:

No of cores:	Cross sectional area [mm <sup>2</sup> ]
3	120

### Texiline Heli Twist Cu

#### Construction:

Conductors: Plain, stranded copper class 5  
 Core insulation: HF XLPE  
 Screen: Cu wire braid and Cu/PET foil  
 Outer sheath: SHF 1

3 single core cables twisted together in triplex construction without common outer sheath.

No of cores:	Cross sectional area [mm <sup>2</sup> ]
3 x 1	35, 50, 70, 95, 120, 150

## Application/Limitation

The requirements of SOLAS Amendments Chapter II-1, Part D, Reg. 45, 5.2 (provision to be taken to limit Fire Propagation along Bundles of Cables or Wires) are fulfilled without any additional measures.

## Type Approval documentation

## Tests carried out

Standard	Release	General description	Limitation
DNV CP-0399	2021-08	Electric cables.	
IEC 60092-350	2020-01	Electrical installations in ships - Part 350: General construction and test methods of power, control and instrumentation cables for shipboard and offshore applications	
IEC 60092-360	2021-01	Electrical installations in ships - Part 360: Insulating and sheathing materials for shipboard and offshore units, power, control, instrumentation and telecommunication cables	
IEC 60092-353	2016-09	Electrical installations in ships - Part 353: Power cables for rated voltages 1 kV and 3 kV	
IEC 60332-3-22	2018-07	Tests on electric and optical fibre cables under fire conditions - Part 3-22: Test for vertical flame spread of vertically mounted bunched wires or cables - Category A	Charred portion of sample does not exceed 2,5m above bottom edge of burner.
IEC 60754-1	2019-11	Test on gases evolved during combustion of materials from cables - Part 1: Determination of the halogen acid gas content	Low Halogen: <0,5% Halogen
IEC 60754-2	2019-11	Test on gases evolved during combustion of materials from cables - Part 1: Determination of the halogen acid gas content	Halogen free: pH > 4,3 Conductivity < 10µS/mm
IEC 61034-1/2	2019-11	Measurement of smoke density of cables burning under defined conditions – Part 1: Test apparatus Part 2: Test procedure and requirements	Low smoke Light transmittance >60%

## Marking of product

AMOKABEL RXZ EMC – size – IEC 60092-353- IEC 60332-3-22 - DNVGL 0,6/1kV - YYWW or  
AMOKABEL RXZ VFD EMC – size – IEC 60092-353 - IEC 60332-3-22 -DNV - 1,8/3kV – YYWW or  
AMOKABEL RXZ VFD EMC 3G –size – IEC 60092-353 - IEC 60332-3-22 - DNV 1,8/3kV - YYWW or  
AMOKABEL RXZ VFD EMC Soft – size – IEC 60092-353 - IEC 60332-3-22 -DNV 1,8/3kV – YYWW or  
AMOKABEL TEXILine Heli Twist Cu EMC – size – IEC 60092-353 - IEC 60332-3-22 -DNV 1,8/3kV – YYWW

## Periodical assessment

The scope of the periodical assessment is to verify that the conditions stipulated for the Type approval are complied with and that no alterations are made to the product design or choice of materials.

The main elements of the assessment are:

- Inspection on factory samples, selected at random from the production line (where practicable)
- Results from Routine tests (RT) and selected type tests (ref. to applicable class programs) checked (if not available these tests shall be carried out)
- Review of type approval documentation
- Review of possible change in design, materials and performance
- Ensuring traceability between manufacturer's product type marking and Type Approval Certificate.

Periodical assessment is to be performed after 2 years and after 3.5 years. A renewal assessment will be performed at renewal of the certificate.

END OF CERTIFICATE