

Certificate of Product Approval

Licensee:
Amokabel UK Ltd.

Units A1-A3, Ratcher Court, Ratcher Way
Crown Farm Industrial Park, Mansfield, NG19 0FS, Nottinghamshire, United Kingdom

Factory:
Units A1-A3, Ratcher Court, Ratcher Way
Crown Farm Industrial Park, Mansfield, NG19 0FS, Nottinghamshire, United Kingdom

Standard:
BS 8436:2011

Description:
Screened cables

Details:
Nail penetration test carried out at 200amps.

Materials:
Insulation GP 8, Sheath LTS 3

Brand Name:
N/A

Origin Mark:
Safe-T-Shield, FLEXISHIELD

Permissible Approval Marks:

BASEC



BASEC name

BASEC roundel

Signed for and on behalf of the British Approvals
Service for Cables

Tony Lioveri

Date: 26/01/2022

Date of original issue: 21/10/2010

Check BASEC website to verify validity.

Page 1 of 2

BASEC, Presley House, Presley Way, Milton Keynes, MK8 0ES, UK
Registered in England No. 1150237, Tel: +44 (0)1908 267300
Email: mail@basec.org.uk Web: www.basec.org.uk

BSF079 Issue 3 (21-01-2021)



Expiry date:
16/05/2025

Type(s) and Range(s) of Approval

Table / Clause	Code Designation	Conductor Class	Range of Cores	Min Nominal Size -sqmm	Max Nominal Size - sqmm
1	N/A	Class 2	2	1	4
1	N/A	Class 2	3	1	4
1	N/A	Class 2	4	1	4

Signed for and on behalf of the British Approvals Service for Cables

Tony Lioveri

Date: 26/01/2022

Date of original issue: 21/10/2010

Check BASEC website to verify validity.

Page 2 of 2

BASEC, Presley House, Presley Way, Milton Keynes, MK8 0ES, UK
Registered in England No. 1150237, Tel: +44 (0)1908 267300
Email: mail@basec.org.uk Web: www.basec.org.uk

BSF079 Issue 3 (21-10-2021)



Expiry date:
16/05/2025